SECS 9 & 16 T5N R28E WM
UMATILLA COUNTY, OREGON

NO ACQUISITION ON THIS SHEET
SEE McNARY SWITCHYARD, CORRIDORS
AND PREVIOUS LINES

McNARY SWITCHYARD
FOR DETAIL SEE
DRAWING SERIAL 76276

ACSR DRAKE
MWT 1500 at 1/2" ICE

ACSR PHEASANT
6 W 5/8" HS MWT 10500 at 1/2" ICE
COND. MWT 12750 at 1/2" ICE

115 KV CONNECTION
TO McNARY SUBSTATION

ACSR DRAKE-MWT 6000 AT
1/2" ICE

STRUCTURE
DESIGNATION
MC F2
1/6

MCNY FRAN
2-1-7

WASHINGTON GRID — SOUTH ZONE
FACTOR 0.9999899
HORIZONTAL SCALE 1"=200'
VERTICAL SCALE 1"=20'

NO	REVISION	DATE	APPROVED
9	110-00 PP&L PWR LINE X-ING ADDED	AUG 225	DW
8	STRS V3,A,B TYPE CHGD	AUG 225	DW
7	McN-P STR 1/6 RELOC McN-PASCO OPER 115 KV ADD McN-FLOWED SSW CHGD	AUG 225	DW

The conductor curve shown is that used for determining tower locations.
Datum USC&GS Cond. (ACSR DRAKE—MWT 6000 at 1/2" ICE EXCEPT AS NOTED

NO	REVISION	DATE	APPROVED
6	DEF M&S ADDED		
5			
4			
3			
2	PH&S INSULATORS NOTE ADD		
1	SHEDDLE G.STRS ADDED		

INSULATORS M & S 135

UNITED STATES DEPARTMENT OF THE INTERIOR
BONNEVILLE POWER ADMINISTRATION
PORTLAND, OREGON

McNARY—FRANKLIN NO 2
230 KV TRANSMISSION LINE (T 3269')
SHORT MILE 1 FROM McNARY (37161)

RIGHT OF WAY — DESIGN DATA
Approved: W. Foster
Date: 10-28-55
SHEET 1 OF 28
Drawing No. 89701
136-16-B