



The conductor curve shown is that used for determining tower locations ACSR PHEASANT - NWT 16700 at 1/2 ICE INSULATORS M.B.E 15000 LBS		UNITED STATES DEPARTMENT OF THE INTERIOR BONNEVILLE POWER ADMINISTRATION HEADQUARTERS, PORTLAND, OREGON	
ACQ SERIAL 57204		Mc NARY - MAUPIN NO 2 287 KV SINGLE CIRCUIT TRANSMISSION LINE MILE 4 FROM McNARY	
APPROVED FOR RIGHT-OF-WAY FOR CONSTRUCTION	DATE 7-5-54	DESIGNED BY DRAWN BY TRACED BY CHECKED BY	APPROVED DATE 12-29-53 SHEET 4 OF 105 Ser. 79704 Dep. 123-13-D