



HF TYPE F2 65'-65'-65'
6-1/2" SM DRAD GUYS
6'-6" CHAN ANG 3/4" x 10' RODS
2-1/2" SM PA GUYS
2-4' CHAN ANG 3/4" x 7' RODS
2-HX GUYS 1-WOOD STRAIN
INSUL PER STRAND
3-EXPLUSION TUBE
PROTECTOR ASSEMBLIES

The conductor curve shown is that used for determining tower locations
Datum: USCGS Cond: ACSR DRAKE MWT 8000 AT 1/2" ICE

UNITED STATES DEPARTMENT OF THE INTERIOR
BONNEVILLE POWER ADMINISTRATION
PAUL J. RAVEN, ADMINISTRATOR

McNARY - PENDLETON LINE
230 KV SINGLE CIRCUIT TRANSMISSION LINE
MILE 12 ON McNARY

2	PROFILE & STRS ADDED	WHH	APPROVED	DATE	12-7-50	DESIGNED: FWF	DATE	12-7-50	SHEET 12 OF 40
1	STA CHANGED 649+23.5	DKS	TRACED: DGW	DATE	1-51	DRAWN: FWF	DATE	12-7-50	51112
NO.	REVISION	DATE	APPROVED	FOR CONSTRUCTION	DATE	CHECKED: MSJ	DATE	12-7-50	133-01-340-DI