



The conductor curve shown is that used for determining tower locations Datum: USC & GS Cond: ACSR DRAKE — MWT 8000 at 1/2" ICE		UNITED STATES DEPARTMENT OF THE INTERIOR BONNEVILLE POWER ADMINISTRATION PAUL J. RAVER, ADMINISTRATOR	
<b>McNARY - PENDLETON LINE</b> 230 KV SINGLE CIRCUIT TRANSMISSION LINE MILE 23 FROM McNARY		Approved: <i>Richard F. Higgins</i> Date: 10-4-50 Drawn: FWM Traced: MEH Checked: MSH	
REFERENCE DRAWINGS 1 PROFILE & STRS ADDED NO. REVISION DATE APPROVED	DESIGNED: FWF DRAWN: FWM TRACED: MEH CHECKED: MSH	SHEET 23 OF 40 Ser. 51123 Dwg. 133-01-340-D1	FOR CONSTRUCTION EWL: JAW DATE: 6/19/51